

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

Client: Textil Artigas, S.L.

Code: CL-1577

Address: Passatge Indústria, 3 LLIÇÀ D'AMUNT BARCELONA ESPAÑA

Attn: Carles Cabré Alarcón

e-MAIL: carlescabre2009@gmail.com

Tel: 0034 649843066

Fax:


The following sample was (were) submitted and identified by the client as:

Serie :		Job no Report No.: 21-002421
Batch No.:		Receiving Date: 26/02/2021
Reference No.:	VISIBLEMASK/TRANS 60 50 2021 ES001 (según cliente Acabado Virobloc)	Test Start Date: 04/03/2021
Composition indicated:	100% polyamide	Test End Date: 22/03/2021
		Sample description: RAW MATERIAL (MASK)

#SUMMARY OF TEST CONCLUSIONS

SOP description	#Conclusions
#SOP305 - Change of appearance after washing (Garments and fabrics)	Pass
#SOP 342- Bacterial Filtration Efficiency (BFE) - (Test subcontracted to an accredited laboratory)	Pass
#SOP 342- Bacterial Filtration Efficiency (BFE)-After Washing (Test subcontracted to an accredited lab)	See Results
#SOP347 - Determination of breathability (Differential Pressure) by UNE-EN 14683 annex C - Original	Pass
#SOP347 - Determination of breathability (Differential Pressure) by UNE-EN 14683 annex C - After Washing	Pass
SOP106 - Determination of Air Permeability by ISO 9237 (for CWA 17553) - Original	Pass
SOP106 - Determination of Air Permeability by ISO 9237 (for CWA 17553) - After washing	Pass

Sample Tested



-The laboratory is not responsible for the information received by the client (grey shaded fields)
 -Reported results do not include uncertainties (but are available for the customer).
 -Opinions and interpretations expressed herein are outside the scope of accreditation.
 -Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.
 -Test reports without AMSLab seal and authorized signatures are invalid.
 -This document can't be reproduced or modified except in full, without prior given approval of the company.
 -Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

SOP305 - Change of appearance after washing (Garments and fabrics)

ID	ID AMSLab	Description	# Conclusion
3	S-210226-00249	FABRIC MASK MULTICOLOR (AFTER 5 WASHING CYCLES AT 60°C)	Pass
ID	ID AMSLab	Description	# Conclusion
10	S-210226-00256	FABRIC MASK MULTICOLOR (AFTER 10 WASHING CYCLES AT 60°C)	Pass
ID	ID AMSLab	Description	# Conclusion
11	S-210226-00257	FABRIC MASK MULTICOLOR (AFTER 15 WASHING CYCLES AT 60°C)	Pass

	CAS	S-210226-00249	S-210226-00256	S-210226-00257
Change of appearance after washing		No change	No change	No change
Number of cycles		5	10	15
Washing Temperature		60°C	60°C	60°C

Notes:

Note 1: Washing and drying process applied based on UNE-EN ISO 6330:2012

Note 2:

- Detergent: 20 gr of Commercial detergent / - Drying procedure: Air dry without tumble dry.
- n.a.: not applicable
- Requirement: No obvious change/colour/shape/appearance/seams/embroidery/trimmings/applications

Note 3 - Meaning of the grades of change of appearance:

- No change in appearance after washing and drying process
- Slight change in appearance after washing and drying process
- Moderate change in appearance after washing and drying process
- Severe change in appearance after washing and drying process

SOP 342- Bacterial Filtration Efficiency (BFE) - (Test subcontracted to an accredited laboratory)

ID	ID AMSLab	Description	# Conclusion
12	S-210308-00038	FABRIC FOR MASK MULTICOLOR (ORIGINAL)	Pass

	CAS	S-210308-00038
Test 1: Bacterial Filtration Efficiency		90.1
Test 1: Number of Bacteria		298
Test 2: Bacterial Filtration Efficiency		90.2
Test 2: Number of Bacteria		300
Test 3: Bacterial Filtration Efficiency		90.2
Test 3: Number of Bacteria		295

- The laboratory is not responsible for the information received by the client (grey shaded fields)
- Reported results do not include uncertainties (but are available for the customer).
- Opinions and interpretations expressed herein are outside the scope of accreditation.
- Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.
- Test reports without AMSLab seal and authorized signatures are invalid.
- This document can't be reproduced or modified except in full, without prior given approval of the company.
- Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

	CAS	S-210308-00038
Test 4: Bacterial Filtration Efficiency		90.2
Test 4: Number of Bacteria		294
Test 5: Bacterial Filtration Efficiency		90.3
Test 5: Number of Bacteria		292

Test Method: EN 14683:2019+AC:2019 (TS EN 14683+AC:2019) Annex-B / Medical Face Masks - Requirements and Test Methods

Requirements by specifications:

Spanish specification UNE 0064:2020: $\geq 95\%$

Spanish specification UNE 0065:2020: $\geq 90\%$

European specification CWA 17553:2020: Level $\geq 90\%$ and

European specification CWA 17553:2020: Level $\geq 70\%$

Other requirements:

- Surgical Mask type I by UNE-EN 14683: $\geq 95\%$

- Surgical Mask type II by UNE-EN 14683: $\geq 98\%$

- Surgical Mask type IIR by UNE-EN 14683: $\geq 98\%$

Report unit Bacterial Filtration Efficiency = %

Report unit Number of Bacteria = cfu/mL

A specimen of the mask material is clamped between a impactor and an aerosol chamber. An aerosol of Staphylococcus aureus is introduced into the aerosol chamber and drawn through the mask material and the impactor under vacuum. The bacterial filtration efficiency of the mask is given by the number of colony forming units passing through the medical face mask material expressed as a percentage of the number of colony forming units present in the challenge aerosol.

Test Flow Rate: 28,3 L/min

Test Flow Time: 2 minute

Sample Sizes: 10x10 cm²

Microorganism: Staphylococcus aureus ATCC 6538

Bacterial concentration (cfu/ml): 5×10^5 cfu/ml

Incubation conditions: 24 hour, 35C \pm 2C

Positive control sample average of number of Bacteria (C): 3.0×10^3 cfu/ml

(*) Test subcontracted and accredited laboratory (EKOTEKS LABORATUVAR VE GÖZETM HZMETLER A. .) for medical mask for tests (EN 14683). Results in subcontracted report number: 21009195

The Turkish Accreditation Agency (TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation (EA) and of the International Laboratory Accreditation (ILAC) for the Mutual recognition of test reports.

EKOTEKS LABORATUVAR VE GÖZETM HZMETLER A. . Deney Laboratuvar, is accredited by TURKAK under registration number (AB-0583-T) for ISO 17025:2017 as test laboratory.

SOP 342- Bacterial Filtration Efficiency (BFE)-After Washing (Test subcontracted to an accredited lab)

ID	ID AMSLab	Description	# Conclusion
13	S-210308-00039	FABRIC FOR MASK MULTICOLOR (AFTER 5 WASHING CYCLES AT 60°C)	See Results
ID	ID AMSLab	Description	# Conclusion
14	S-210308-00040	FABRIC FOR MASK MULTICOLOR (AFTER 10 WASHING CYCLES AT 60°C)	See Results
ID	ID AMSLab	Description	# Conclusion
15	S-210308-00041	FABRIC FOR MASK MULTICOLOR (AFTER 15 WASHING CYCLES AT 60°C)	See Results

-The laboratory is not responsible for the information received by the client (grey shaded fields)

-Reported results do not include uncertainties (but are available for the customer).

-Opinions and interpretations expressed herein are outside the scope of accreditation.

-Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.

-Test reports without AMSLab seal and authorized signatures are invalid.

-This document can't be reproduced or modified except in full, without prior given approval of the company.

-Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

15	S-210308-00041	CYCLES AT 60°C)	See Results
----	----------------	-----------------	-------------

	CAS	S-210308-00039	S-210308-00040	S-210308-00041
Test 1: Bacterial Filtration Efficiency		88.9	86.6	84.8
Test 1: Number of Bacteria		332	401	455
Test 2: Bacterial Filtration Efficiency		88.6	86.4	84.5
Test 2: Number of Bacteria		341	409	464
Test 3: Bacterial Filtration Efficiency		88.5	86.0	84.1
Test 3: Number of Bacteria		346	419	476
Test 4: Bacterial Filtration Efficiency		88.7	86.5	84.5
Test 4: Number of Bacteria		340	406	465
Test 5: Bacterial Filtration Efficiency		88.6	86.1	84.8
Test 5: Number of Bacteria		342	417	455

Test Method: EN 14683:2019+AC:2019 (TS EN 14683+AC:2019) Annex-B / Medical Face Masks - Requirements and Test Methods

Requirements by specifications:

Spanish specification UNE 0064:2020: $\geq 95\%$

Spanish specification UNE 0065:2020: $\geq 90\%$

European specification CWA 17553:2020: Level $\geq 90\%$ and

European specification CWA 17553:2020: Level $\geq 70\%$

Other requirements:

- Surgical Mask type I by UNE-EN 14683: $\geq 95\%$

- Surgical Mask type II by UNE-EN 14683: $\geq 98\%$

- Surgical Mask type IIR by UNE-EN 14683: $\geq 98\%$

Report unit Bacterial Filtration Efficiency = %

Report unit Number of Bacteria = cfu/mL

A specimen of the mask material is clamped between a impactor and an aerosol chamber. An aerosol of Staphylococcus aureus is introduced into the aerosol chamber and drawn through the mask material and the impactor under vacuum. The bacterial filtration efficiency of the mask is given by the number of colony forming units passing through the medical face mask material expressed as a percentage of the number of colony forming units present in the challenge aerosol.

Test Flow Rate: 28,3 L/min

Test Flow Time: 2 minute

Sample Sizes: 10x10 cm²

Microorganism: Staphylococcus aureus ATCC 6538

Bacterial concentration (cfu/ml): 5x10E5 cfu/ml

Incubation conditions: 24 hour, 35C \pm 2C

Positive control sample average of number of Bacteria (C): 3.0x10E3 cfu/ml

(*) Test subcontracted and accredited laboratory (EKOTEKS LABORATUVAR VE GÖZETM HZMETLER A. .) for medical mask for tests (EN 14683). Results in subcontracted report number: 21009196 for samples for 5 washing cycles, 21009199 for samples for 10 washing cycles and 21009197 for samples for 15 washing cycles.

The Turkish Accreditation Agency (TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation (EA) and of the International Laboratory Accreditation (ILAC) for the Mutual recognition of test reports.

EKOTEKS LABORATUVAR VE GÖZETM HZMETLER A. . Deney Laboratuvar, is accredited by TURKAK under registration number (AB-

-The laboratory is not responsible for the information received by the client (grey shaded fields)

-Reported results do not include uncertainties (but are available for the customer).

-Opinions and interpretations expressed herein are outside the scope of accreditation.

-Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.

-Test reports without AMSLab seal and authorized signatures are invalid.

-This document can't be reproduced or modified except in full, without prior given approval of the company.

-Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

0583-T) for ISO 17025:2017 as test laboratory.

SOP347 - Determination of breathability (Differential Pressure) by UNE-EN 14683 annex C - Original

ID	ID AMSLab	Description	# Conclusion
1	S-210226-00247	FABRIC MASK MULTICOLOR	Pass

	CAS	S-210226-00247
Average Differential pressure (Pa/cm2)		42
Value 1 Differential pressure (Pa/cm2)		43
Value 2 Differential pressure (Pa/cm2)		41
Value 3 Differential pressure (Pa/cm2)		42
Value 4 Differential pressure (Pa/cm2)		42
Value 5 Differential pressure (Pa/cm2)		43

Notes:

- Note 1: Applied standard UNE-EN 14683:2019+AC:2019 Annex C for breathability (Differential Pressure)
- Note 2: For requirements: Spanish Specification UNE 0064-1, 0064-2, 0065 and European Specification CWA 17553
- Note 3: Size of test specimen: 4.9 cm2
- Note 4: Tested area of the test specimen: 2.5 cm
- Note 5: Flow of air: (8 ± 0.2) l/min
- Note 6: Report Unit: Pa and P (Pa/cm2)
- Note 7: Number of samples tested: 5 / Number of measurements: 5
- Note 8: Conditioned samples: 4 hours at 21 ± 5 °C and 85 ± 5 HR
- Note 9: n.a. = not applicable

Requirements by specifications:

- Non-reusable Hygienic Mask by UNE 0064-1-2: < 60 Pa/cm2
- Reusable Hygienic Mask by UNE 0065: < 60 Pa/cm2
- European specification CWA 17553:2020: <= 70 Pa/cm2

Other requirements:

- Surgical Mask type I by UNE-EN 14683: < 40 Pa/cm2
- Surgical Mask type II by UNE-EN 14683: < 40 Pa/cm2
- Surgical Mask type IIR by UNE-EN 14683: < 60 Pa/cm2

Specific Notes:

- (**) The result is out of specifications

- The laboratory is not responsible for the information received by the client (grey shaded fields)
- Reported results do not include uncertainties (but are available for the customer).
- Opinions and interpretations expressed herein are outside the scope of accreditation.
- Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.
- Test reports without AMSLab seal and authorized signatures are invalid.
- This document can't be reproduced or modified except in full, without prior given approval of the company.
- Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

SOP347 - Determination of breathability (Differential Pressure) by UNE-EN 14683 annex C - After Washing

ID	ID AMSLab	Description	# Conclusion
2	S-210226-00248	FABRIC MASK MULTICOLOR (AFTER 5 WASHING CYCLES AT 60°C)	Pass
ID	ID AMSLab	Description	# Conclusion
6	S-210226-00252	FABRIC MASK MULTICOLOR (AFTER 10 WASHING CYCLES AT 60°C)	Pass
ID	ID AMSLab	Description	# Conclusion
7	S-210226-00253	FABRIC MASK MULTICOLOR (AFTER 15 WASHING CYCLES AT 60°C)	Pass

	CAS	S-210226-00248	S-210226-00252	S-210226-00253
Average Differential pressure (Pa/cm2)		43	48	52
Value 1 Differential pressure (Pa/cm2)		43	49	54
Value 2 Differential pressure (Pa/cm2)		44	47	53
Value 3 Differential pressure (Pa/cm2)		44	47	51
Value 4 Differential pressure (Pa/cm2)		42	48	51
Value 5 Differential pressure (Pa/cm2)		43	48	53

Notes:

- Note 1: Applied standard UNE-EN 14683:2019+AC:2019 Annex C for breathability (Differential Pressure)
 Note 2: For requirements: Spanish Specification UNE 0064-1, 0064-2, 0065 and European Specification CWA 17553
 Note 3: Size of test specimen: 4.9 cm²
 Note 4: Tested area of the test specimen: 2.5 cm²
 Note 5: Flow of air: (8 ± 0.2) l/min
 Note 6: Report Unit: Pa and P (Pa/cm²)
 Note 7: Number of samples tested: 5 / Number of measurements: 5
 Note 8: Conditioned samples: 4 hours at 21 ± 5 °C and 85 ± 5 HR
 Note 9: n.a. = not applicable

Requirements by specifications:

- Non-reusable Hygienic Mask by UNE 0064-1-2: < 60 Pa/cm²
- Reusable Hygienic Mask by UNE 0065: < 60 Pa/cm²
- European specification CWA 17553:2020: ≤ 70 Pa/cm²

Other requirements:

- Surgical Mask type I by UNE-EN 14683: < 40 Pa/cm²
- Surgical Mask type II by UNE-EN 14683: < 40 Pa/cm²
- Surgical Mask type IIR by UNE-EN 14683: < 60 Pa/cm²

Specific Notes:

- (**) The result is out of specifications

- The laboratory is not responsible for the information received by the client (grey shaded fields)
- Reported results do not include uncertainties (but are available for the customer).
- Opinions and interpretations expressed herein are outside the scope of accreditation.
- Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.
- Test reports without AMSLab seal and authorized signatures are invalid.
- This document can't be reproduced or modified except in full, without prior given approval of the company.
- Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

SOP106 - Determination of Air Permeability by ISO 9237 (for CWA 17553) - Original

ID	ID AMSLab	Description	# Conclusion
4	S-210226-00250	FABRIC MASK MULTICOLOR	Pass

	CAS	S-210226-00250
(I.C. 95%) - Confidence Interval \pm		2.7
Mean Value air permeability (l/m ² /seg)		147.0
Standard deviation		3.7
Value 10 (l/m ² /seg)		142.0
Value 1 (l/m ² /seg)		147.0
Value 2 (l/m ² /seg)		148.0
Value 3 (l/m ² /seg)		151.0
Value 4 (l/m ² /seg)		145.0
Value 5 (l/m ² /seg)		153.0
Value 6 (l/m ² /seg)		146.0
Value 7 (l/m ² /seg)		151.0
Value 8 (l/m ² /seg)		144.0
Value 9 (l/m ² /seg)		143.0

Notes:

Note 1: Applied standard UNE-EN 14683:2019 and European Specification CWA 17553:2020

Note 2: Applied pressure: 100 Pa

Note 3: Applied area: 5 cm²

Note 4: Report Unit: l/m²/seg (= mm/seg)

Note 5: Number of measurements: 10

Note 6: Conditioned samples: 24 hours at 20 \pm 2 °C and 65 \pm 4 HR

Note 7: n.a. = not applicable

Note 8: Standard deviation units and I.C. 95% units: l/m²/seg

Requirements by specifications:

- European specification CWA 17553:2020: \geq 96 l/m²/s

Specific Notes:

(**) The result is out of specifications

SOP106 - Determination of Air Permeability by ISO 9237 (for CWA 17553) - After washing

ID	ID AMSLab	Description	# Conclusion
5	S-210226-00251	FABRIC MASK MULTICOLOR (AFTER 5 WASHING CYCLES AT 60°C)	Pass
ID	ID AMSLab	Description	# Conclusion
8	S-210226-00254	FABRIC MASK MULTICOLOR (AFTER 10 WASHING CYCLES AT 60°C)	Pass
ID	ID AMSLab	Description	# Conclusion
9	S-210226-00255	FABRIC MASK MULTICOLOR (AFTER 15 WASHING CYCLES AT 60°C)	Pass

-The laboratory is not responsible for the information received by the client (grey shaded fields)

-Reported results do not include uncertainties (but are available for the customer).

-Opinions and interpretations expressed herein are outside the scope of accreditation.

-Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.

-Test reports without AMSLab seal and authorized signatures are invalid.

-This document can't be reproduced or modified except in full, without prior given approval of the company.

-Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included in the ENAC accreditation scope

9	S-210226-00255	CYCLES AT 60°C)	Pass
---	----------------	-----------------	------

	CAS	S-210226-00251	S-210226-00254	S-210226-00255
(I.C. 95%) - Confidence Interval ±		3.9	2.9	2.5
Mean Value air permeability (l/m2/seg)		127.6	122.1	111.5
Standard deviation		5.5	4.1	3.5
Value 10 (l/m2/seg)		120.0	121.0	110.0
Value 1 (l/m2/seg)		132.0	126.0	117.0
Value 2 (l/m2/seg)		128.0	121.0	116.0
Value 3 (l/m2/seg)		129.0	119.0	109.0
Value 4 (l/m2/seg)		124.0	125.0	111.0
Value 5 (l/m2/seg)		124.0	130.0	112.0
Value 6 (l/m2/seg)		136.0	118.0	108.0
Value 7 (l/m2/seg)		127.0	116.0	106.0
Value 8 (l/m2/seg)		135.0	122.0	114.0
Value 9 (l/m2/seg)		121.0	123.0	112.0

Notes:

Note 1: Applied standard UNE-EN 14683:2019 and European Specification CWA 17553:2020

Note 2: Applied pressure: 100 Pa

Note 3: Applied area: 5 cm²

Note 4: Report Unit: l/m2/seg (= mm/seg)

Note 5: Number of measurements: 10

Note 6: Conditioned samples: 24 hours at 20 ± 2 °C and 65 ± 4 HR

Note 7: n.a. = not applicable

Note 8: Standard deviation units and I.C. 95% units: l/m2/seg

Requirements by specifications:

- European specification CWA 17553:2020: >= 96 l/m2/s

Specific Notes:

(**) The result is out of specifications

- The laboratory is not responsible for the information received by the client (grey shaded fields)
- Reported results do not include uncertainties (but are available for the customer).
- Opinions and interpretations expressed herein are outside the scope of accreditation.
- Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.
- Test reports without AMSLab seal and authorized signatures are invalid.
- This document can't be reproduced or modified except in full, without prior given approval of the company.
- Any printed copy of this document is copy from the original digital document.

Job No./Report No: 21-002421

Date: 22/03/2021

SOP and results with (#) are not included
in the ENAC accreditation scope

Issue Date: 22/03/2021

Signed: Manuel Lolo


amslab
Applied Mass Spectrometry Laboratory S.L.
C.I.F. B - 27.380.914

General Manager

Signed: Pablo Perez


amslab
Applied Mass Spectrometry Laboratory S.L.
C.I.F. B - 27.380.914

Chemical Lab Manager

Signed: Esteban Ramirez


amslab
Applied Mass Spectrometry Laboratory S.L.
C.I.F. B - 27.380.914

Physical Lab Manager

Test report reviewed by Esteban Ramírez (Physical Tests) and Pablo Pérez (Chemical Tests)

- The laboratory is not responsible for the information received by the client (grey shaded fields)
- Reported results do not include uncertainties (but are available for the customer).
- Opinions and interpretations expressed herein are outside the scope of accreditation.
- Unless otherwise stated the result shown in this test report refer only the sample/s tested and such sample/s are retained for 30 days only.
- Test reports without AMSLab seal and authorized signatures are invalid.
- This document can't be reproduced or modified except in full, without prior given approval of the company.
- Any printed copy of this document is copy from the original digital document.